

OFFICE OF THE CHIEF DISTRICT MEDICAL & PUBLIC HEALTH OFFICER
(District Head Quarter Hospital , At / PO / Dist :- Jagatsinghpur-754103)



Letter no 949

Dated 14-11-2025

To

The Principal
ST. XAVIER'S HIGH SCHOOL
Town hall, Jagatsinghpur
Mail ID- sxhs_jspur@yahoo.com

Sub: - Regarding application for safe drinking water & sanitation certification.

Ref: - Letter No – SXHS/1846/2025-26 Dated: - 25.10.2025, of your office

Sir,

With reference to the letter no. & subject cited above, this is to inform you that ,the Microbiologist of District Headquarter Hospital, Jagatsinghpur inspected your institute on 31.10.2025 for safe drinking water & sanitation certification as below.

- ❖ Source of drinking water for all students & staff.
 - All installation certificates/service reports of Aqua guard needs to be submitted.
- ❖ Waterlogging near overhead water tank to be removed for better hygienic of the school campus.
- ❖ General cleanness near the over head tank and campus needs to be done regularly.
- ❖ All toilets for students needs to be properly cleaned regularly.

So, you are requested that the hygienic condition of your campus premises should be improved.

This is for favor of your information & necessary action.

Yours Faithfully

[Signature]
14/11/25

District Public Health Officer
Jagatsinghpur

PRINCIPAL
ST. XAVIER'S HIGH SCHOOL
JAGATSINGHPUR-754103

[Signature]
SECRET
ST. XAVIER'S HIGH SCHOOL
JAGATSINGHPUR, ODISHA

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**


No 997

Dated 13-01-2026

It is certified that an inspection team headed by Dr. Santosh Kumar Behera. DPHO, & Pradipta Kumar Swain, Microbiologist DHH, Jagatsinghpur (Name of Officers with Designation) from District Head Quarter Hospital, Jagatsinghpur (Name of Department/ Office) inspected the **ST. XAVIER'S HIGH SCHOOL, NEAR TOWN HALL** (Name & Address of the School) on **13.01.2026** and found that the **ST. XAVIER'S HIGH SCHOOL** (Name of the School) has safe drinking water facilities for the students and members of staff of the institution and are maintaining the hygienic sanitation condition in the school building & the Campus as per the norms prescribed by the Central/ State/ U. T Govt.

The Above valid for a period of One Year

Signature with Seal


Dr. Santosh Kumar Behera
District Public Health Officer
DHH, Jagatsinghpur

District Public Health Officer
Jagatsinghpur

To

The Principal

ST. XAVIER'S HIGH SCHOOL

NEAR TOWN HALL

Jagatsinghpur

(Name and Address of the Institution.)


SECRETARY
ST. XAVIERS HIGH SCHOOL
JAGATSINGHPUR, ODISHA


OFFICE OF THE ASSISTANT ENGINEER,
P.H. SECTION, JAGATSINGHPUR

No. 348 Dt 25/11/2025

It is certified that I Manas Ranjan Murmu, Assistant Engineer, P.H. Section, Jagatsinghpur has inspected the St, xavier's High School, Jagatsinghpur On dt- 25.11.2025 and found that the school has safe drinking water for the student and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Government of Odisha.

To
The Principal
St. Xavier High School
Jagatsinghpur-754103

Yours faithfully


Assistant Engineer,
P.H. Section, Jagatsinghpur


PRINCIPAL
ST. XAVIER'S HIGH SCHOOL
JAGATSINGHPUR-754103


SECRETARY
ST. XAVIERS HIGH SCHOOL
JAGATSINGHPUR, ODISHA

TEST REPORT

Test Date: -From 27/10/2025

to

29/10/2025

Water Testing Divisonal Laboratory Jagatsinghpur C/O LTC COMMERCIAL COMPANY PVT. LTD, Jogdhari, Pin-754103

Sr.No.			ST. Xavier High school, Near Town Hall								Acceptable Limit	PERMISSIBLE LIMIT
				Tap Water								
	PARAMETERS	TEST METHOD		Sample								
1	pH	IS 3025 (P-11)	6.87								6.5-8.5	6.5-8.5
2	Conductivity (µs/cm)	IS 3025 (P-14)	532								NA	NA
3	Turbidity (NTU)	IS 3025 (P-10)	0.23								1 NTU	5 NTU
4	Free Residual Chlorine (mg/l)	APHA 4500 G	0.10								0.2 mg/l	1 mg/l
5	Total Dissolved Solids (mg/l)	IS 3025 (P-16)	345								500 mg/l	2000 mg/l
6	Odour, TON	IS 3025 (P-6)	Agreeable								Agreeable	Agreeable
7	Colour (Pt.Co)	IS 3025 (P-4)	2								5.0	15
8	Ammonia as N (mg/l)	IS 3025 (P-34)	0.29								0.5 mg/l	0.5 mg/l
9	Alkalinity(as CaCO3) (mg/l)	IS 3025 (P-23)	150								200 mg/l	600 mg/l
10	Hardness (as CaCO3) (mg/l)	IS 3025 (P-21)	152								200 mg/l	600 mg/l
11	Calcium (as Ca) (mg/l)	IS 3025 (P-40)	56.91								75 mg/l	200 mg/l
12	Magnesium (as Mg) (mg/l)	IS 3025 (P-46)	2.43								30 mg/l	100 mg/l
13	Chloride (as Cl) (mg/l)	IS 3025 (P-32)	58.06								250 mg/l	1000 mg/l
14	Dissolve Oxygen (mg/l)	APHA 4500 OH									NA	NA
15	Sodium (mg/l)	IS 3025 (P-45)	10.35								NA	NA
16	Potassium (mg/l)	IS 3025 (P-45)	2.08								NA	NA
17	Iron (as Fe) (mg/l)	IS 3025 (P-53)	0.03								1 mg/l	1 mg/l
18	Fluoride (as F) (mg/l)	IS 3025 (P-60)	0.02								1 mg/l	1.5 mg/l
19	Nitrate (as NO3) (mg/l)	IS 3025 (P-34)	3.67								45 mg/l	45 mg/l
20	Manganese (mg/l)	IS 3025 (P-59)	0.069								0.1 mg/l	0.3 mg/l
21	Sulphate (mg/l)	IS3025 (P-24)	3.83								200 mg/l	400 mg/l
22	Coliform Organism (MPN/100 ml)	IS 1622-1981	Absent								NA	NA
23	E.Coli (Present/Absent) (MPN/100 ml)	IS 1622-1981	Absent								NA	NA

Note: For SW-Biological Method is be Followed (IS.1622-1981) TW - Tube Well, PW- Production Well, SW- Surface Water, DS- Distribution System,BDL-Below Detection Limit,NR-Not Required (As per Agreement).

Issue No:01
Issue Date:01.01.2022

Debas
29/10/2025

PRINCIPAL
ST. XAVIER'S HIGH SCHOOL
JAGATSINGHPUR-754103

SECRETARY
ST. XAVIER'S HIGH SCHOOL
JAGATSINGHPUR, ODISHA

Debas
29/10/25

Revision No:00
Revision Date:00